PRO-EJ SUGGESTED ARCHITECT SPECIFICATIONS

Model:
The electrical operator will be a Nice Model PRO-EJ as manufactured by Nice Group Canada Inc. Related work – Door preparation, miscellaneous or structural metal work, field electrical wiring, wire, conduit, fuses, and disconnect switches are in the scope of work of other division trades.

Products:
Supply Nice Model Pro-EJ industrial duty, belt drive jackshaft operator(s) available in 1/3 and 1/2 HP single phase or three phase.

General:
Provide CSA listed, UL 325 2010 tested and approved electric door operator assembly of size and capacity recommended by door manufacturer. External entrapment device monitoring built in to control circuit complete with electric motor and factor pre-wired controls, conduit and wiring to motor and accessories required for proper operation by others.

Electric Motor:
Motor shall be high torque, 1725 RPM continuous duty, instant reversible, industrial type, capacitor start (1-phase), protected by automatic thermal overload device (3-phase) or an external reset overload device (1-phase).

Control Circuit:
24V NEC Class 2 Circuit with a 40VA transformer, 24V fused control circuit to protect against short circuit.

Motor Starter, Controls, Enclosure:
Motor control circuit shall incorporate an across the line magnetic reversing starter electrically and mechanically interlocked, motor controls shall be in a Nema-1 enclosure. Controls and control enclosure shall conform to ANSI/NEMA ICS 1, ICS 2 and ICS6. A Nema-1 3 button control station OPEN/CLOSE/STOP and Nice compatible monitored photocells shall be provided as standard equipment.

Frame and Reduction:
Speed reduction will be heavy duty 5L V-belt, second and third stage reduction #41 roller chain and sprockets, operator shall utilize #50 roller chain and sprockets on final drive. All shafts shall be coated in black oxide for maximum corrosion resistance, permanently lubricated and sealed ball bearings on all drive shafts. All drive sprockets drilled and pinned and set with locktite. Operator shall be capable of driving door at a speed of 8”-10” per second.

Adjustable Clutch:
Operator shall be equipped with an adjustable friction clutch to prevent door and operator damage.

Emergency Operation:
Equipped with a floor level emergency disconnect with electrical cut-out switch for egress to allow for opening of door by manual operation or spring tension.

Load Sensing Feature:
Equipped with a mechanical load sensing mechanism that will detect a locked or jammed door and stop unit from operation.

Mechanical Brake:
Equipped with mechanical brake to stop and hold the door in position. Solenoid brake optional.

Limit Switches:
Fully adjustable, rotary driven linear type limit switch mechanism shall synchronize the operator with the door. Low friction oil impregnated powder metal limit cams, fitted on threaded steel shaft, rotating on oilite self lubricating bronze bushings. The motor shall be removable without affecting the limit switch settings.

Trolley Assembly:
2”x2” 12 guage galvanized right angle steel rails with quiet, long quick disconnect cast aluminum carriage with black oxide coated steel rail spacers.

Execution:
Install the motor operator in accordance with Nice Group Canada Inc. instruction and standards and in compliance with applicable federal, state or local regulations.

Warranty:
Nice Group Canada Inc. warrants that its operators shall be free of any defects in materials and workmanship for a period of 2 years.